

CDH Boise Bathroom Remodel / FAC 25-10

Question	RFP Section	RFP Page	Question	Response
1	General		What will be the work hours for this project?	Monday through Friday, 8:00 a.m. to 5:00 p.m. or earlier in the day if agreed upon.
2	General		Do we need to build any temp walls to seal off these bathrooms from the hallway or just closed sealed doors while work is going on?	No temporary walls will be needed. Doors will be kept shut and a visqueen blanket used as a dust barrier.
3	General		Assuming for access of hauling materials in we will use the front doors for the front bathrooms and back doors to the courtyard area for the back bathrooms unless stated otherwise?	That is correct.
4	General		Will there be any parking spots designated for a laydown yard or construction parking and if so where?	Designated parking and laydown will be in the front parking lot but can be relocated based on needs of the contractor.
5	General		What is the anticipated start date of the project?	Once contract is awarded & materials are procured, contractor will submit schedule for CDH to approve.
6	General		Which set of restrooms would you like us to work on first?	We would like to start with the main hallway restrooms.
7	General		Is there a date that you expect us to be done by or are we just building the schedules for the RFP to what we think we will need?	Work to be completed no longer than five (5) months from start of project.
8	General		Is there a time we can meet onsite with subcontractors to walk the space?	Yes. Please contact the RFP lead at bids@cdh.idaho.gov to schedule a time to walk the project. No questions will be answered during the walk-through.
9	HVAC		Are the existing exhaust fans to remain the same since we don't have any HVAC plans?	See attached plans (reference note 23.04) for adding on to existing exhaust fan system.
10				
11				
12				
13				
14				
15				
16				